



I 4065

ABE.TEC

Inspekční orgán č. 4065

Inspection Body No. 4065 Company ABE.TEC, s.r.o.
accredited by the Czech Accreditation Institute acc. to the ČSN EN ISO/IEC 17020,

on the basis of the Inspection Report No. **01/20** from the inspection performed
on **23. 1. 2020**, this Inspection Report being an integral part of this Inspection Certificate,

issued for:

Fortemix s.r.o.
Kirilovova 812, 739 21 Paskov
Company ID: 26868211

INSPECTION CERTIFICATE

No. 01/20

confirming that

floor PVC tiles

(Decor, Industry, Invisible, Light)

meet

Customer's requirements, i.e. the voltage value does not exceed 2000 V

The results of the inspection were obtained under the conditions and using the procedures specified
in the Inspection Report and relate only to the time and place of the inspection.

Date of issue: 29. 1. 2020



M. Abel
Ing. Martin Abel
Inspection Body Manager